



Name of Sampler: Liz Carr
Date Collected: 01/09/2020
School Name: Chief Joseph Middle School
School Code: 2785
School District: Richland
School Address: 504 Wilson Street, Richland WA 99354
School County: Benton
Number of Samples Collected: 64
School Point of Contact (POC): Jeff Lettau
POC Title: Director Facilities & Operations
POC Email: Jeffrey.lettau@rsd.edu
POC Phone Number: 509-578-8381
Date Samples Sent to Lab: 01/09/2020
Date Samples Received by Lab: 01/17/2020
Shipment Tracking Number: 8133 8049 6255, 8133 8049 6266

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
31632	FirstDraw	other	Blank	<1	01/24/2020	
31633	FirstDraw	Bubbler	Band room Choral hallway	<1	01/24/2020	
31634	FirstDraw	Tap	Rm 401 Choral	<1	01/24/2020	
31635	FirstDraw	Tap	Rm 405	<1	01/24/2020	
31636	FirstDraw	Bubbler	Lobby drinking fountain	<1	01/24/2020	
31637	FirstDraw	Tap	Rm 106 staff	<1	01/24/2020	
31638	FirstDraw	Bubbler	Rm 108	2	01/24/2020	
31639	FirstDraw	Tap	Rm 108	5	01/24/2020	
31640	FirstDraw	Bubbler	Rm 110	<1	01/24/2020	
31641	FirstDraw	Tap	Rm 110	1	01/24/2020	
31642	FirstDraw	Bubbler	Rm 112	<1	01/24/2020	
31643	FirstDraw	Tap	Rm 112	3	01/24/2020	
31644	FirstDraw	Bubbler	Rm 118	<1	01/24/2020	
31645	FirstDraw	Tap	Rm 118	2	01/24/2020	
31646	FirstDraw	Tap	Rm 120 science room	3	01/24/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
31647	FirstDraw	Bubbler	Rm 129	<1	01/24/2020	
31648	FirstDraw	Tap	Rm 129	4	01/24/2020	
31650	FirstDraw	Tap	Rm 127	<1	01/24/2020	
31651	FirstDraw	Bubbler	First floor west hallway next to restroom 123	<1	01/24/2020	
31652	FirstDraw	Bubbler	Rm 121	<1	01/24/2020	
31653	FirstDraw	Tap	Rm 121	4	01/24/2020	
31654	FirstDraw	Bubbler	Rm 119	<1	01/24/2020	
31655	FirstDraw	Tap	Rm 119	1	01/24/2020	
31656	FirstDraw	Tap	Rm 117 faculty	3	01/24/2020	
31657	FirstDraw	Tap	Rm 103 Health Room	<1	01/24/2020	
31658	FirstDraw	Tap	Rm 303 Art Room	<1	01/24/2020	Sink Teacher Only
31659	FirstDraw	Tap	Rm 307 Home Economics	<1	01/24/2020	Sink 1 SE sink
31660	FirstDraw	Tap	Rm 307 home economics	1	01/24/2020	Sink 2 East left of sink 1
31661	FirstDraw	Tap	Rm 307	3	01/24/2020	Sink 3 NE
31662	FirstDraw	Tap	Rm 307	23	01/24/2020	Sink 4 NNW
31663	FirstDraw	Tap	Rm 307	<1	01/24/2020	Sink 5 NW
31664	FirstDraw	Tap	Rm 307	9	01/24/2020	Sink 6 West
31665	FirstDraw	Tap	Rm 307	19	01/24/2020	Sink 7 SW
31666	FirstDraw	Tap	Rm 313	44	01/24/2020	
31667	FirstDraw	Bubbler	Cafeteria	<1	01/24/2020	Drinking fountain
31668	FirstDraw	PotFiller	Kitchen rm 334	43	02/10/2020	Right pot filler

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
31669	FirstDraw	PotFiller	Kitchen	142	02/10/2020	Left pot filler
31670	FirstDraw	Tap	Kitchen	1	01/24/2020	Food prep only sink
31671	FirstDraw	Tap	Rm 332 Special Ed	1	01/24/2020	
31672	FirstDraw	Tap	Rm 318 library	4	02/10/2020	
31673	FirstDraw	Bubbler	Rm 202	1	01/24/2020	
31674	FirstDraw	Tap	Rm 202	5	01/24/2020	
31675	FirstDraw	Bubbler	Rm 210	3	01/24/2020	
31676	FirstDraw	Tap	Rm 210	2	01/24/2020	
31677	FirstDraw	Bubbler	Rm 212	<1	01/24/2020	Bubbler leaks
31678	FirstDraw	Tap	Rm 212	<1	01/24/2020	
31679	FirstDraw	Bubbler	Rm 214	1	01/24/2020	
31680	FirstDraw	Tap	Rm 214	1	01/24/2020	
31681	FirstDraw	Bubbler	Rm 216 science room	<1	01/24/2020	
31682	FirstDraw	Tap	Rm 216	4	01/24/2020	
31683	FirstDraw	Tap	Rm 222	1	01/24/2020	
31684	FirstDraw	Bubbler	2nd floor hallway between rm 235 and 236	<1	01/24/2020	Hydration station
31685	FirstDraw	BottleFiller	Hallway between rm 235 and 237	<1	01/24/2020	Hydration station
31686	FirstDraw	Bubbler	Rm 244 gym	<1	01/24/2020	Next to girls locker room
31687	FirstDraw	Bubbler	Rm 251 girls locker room	<1	01/24/2020	
31688	FirstDraw	Bubbler	Gym	<1	01/24/2020	Next to boys locker room

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
31689	FirstDraw	Bubbler	Gym boys locker room	<1	01/24/2020	
31690	FirstDraw	Bubbler	Rm 221	<1	01/24/2020	
31691	FirstDraw	Tap	Rm 221	<1	01/24/2020	
31692	FirstDraw	Bubbler	Rm 219	1	01/24/2020	
31693	FirstDraw	Tap	Rm 219	4	01/24/2020	
31694	FirstDraw	Bubbler	Rm 217	1	01/24/2020	
31695	FirstDraw	Tap	Rm 217	<1	01/24/2020	
31696	FirstDraw	Bubbler	2nd floor hallway across from rm 213	<1	01/24/2020	Drinking fountain